

CERTIFICATE

API Standard 607 7th Edition: 2016

The undersigned, Vincent Sheng, acting with the scope of the contractual requirements entrusted to Bureau Veritas, certifies that the supply:


Valve Model : Series 90D
Valve Type : 2- Piece Flanged End Ball Valve
Valve Size : 2 inch (DN50)
Pressure Rating : Class 150
Drawing No. : V90D-1F-1 rev.1
Body Material : ASTM A351 CF8M/1.4408
Seat Material : PTFE
Ball Material : ASTM A351 CF8M
Stem Material : SS316
Supplied by : MARS VALVE CO., LTD

Tested by Metal Industries Research & Development Centre (MIRDC) and witnessed by Bureau Veritas, per API Standard 607 7th Edition: 2016 at Lung-Tan, Taiwan. Verified in conformity with the requirements of the standard mentioned above.

Client : MARS VALVE CO., LTD
No.83, Sec. 1, Chung-De 8th Road, Taichung City , Taiwan (R.O.C.)
Test Date : 7th Aug 2025
Test Report No. : T11408004

Qualified Range of Valves (according to Clause 7.3 ~ 7.4 of API Standard 607 7th Edition: 2016)

Valve Model : Series 90D
Pressure Rating : Class 150, 300
Valve Size : NPS 2 and below; 2-1/2 ; 3 ; 4 (DN50 and below; 65 ; 80 ; 100)
Body Materials : Austenitic

Etabli à / Issued at	Le / On	Signé par / Signed by	Signature / Signature
Taipei, Taiwan	18 th Aug. 2025	Vincent Sheng	
Certificate No. : TPI25261-1			

* This certificate must be read in conjunction with the test report No. T11408004 of MIRDC.

** This certificate only confirms that the test sample (manufacturing serial number MAR38758-90D-05) complies with the relevant test process.

*** This certificate is subject to the terms of Bureau Veritas General Conditions of Service attached to the agreement signed by the applicant.

**** Detailed of fire test conditions are shown on page 2/2.