



Industry & Facilities Division
Inspection Certificate



CERTIFICATE

API Standard 607 7th Edition: 2016

The undersigned, Bill Su, acting with the scope of the contractual requirements entrusted to Bureau Veritas, certifies that the supply:

Valve Model : Series 91D
Valve Type : 1PC Flanged End Ball Valve (Reduced Bore)
Valve Size : 2 inch (DN50)
Pressure Rating : Class 150
Drawing No. : V91D-1F-1 rev.1
Body Material : ASTM A216 Gr.WCB
Seat Material : RPTFE
Ball Material : CF8M
Stem Material : ASTM A276 SUS316
Supplied by : MARS VALVE CO., LTD

Tested by Metal Industries Research & Development Centre (MIRDC) and witnessed by Bureau Veritas, per API Standard 607 7th Edition: 2016 at Lung-Tan, Taiwan. Verified in conformity with the requirements of the standard mentioned above.

Client : MARS VALVE CO., LTD
No.83, Sec. 1, Chung-De 8th Road, Taichung City, Taiwan (R.O.C.)
Test Date : 29th Oct. 2025
Test Report No. : T11410012-2

Qualified Range of Valves (according to Clause 7.3 ~ 7.4 of API Standard 607 7th Edition: 2016)

Valve Model : Series 91D
Pressure Rating : Class 150; 300
Valve Size : NPS 2 and below; 2-1/2 ; 3 ; 4 (DN50 and below; 65 ; 80 ; 100)
Body Materials : Ferritic

Etabli à / Issued at	Le / On	Signé par / Signed by	Signature / Signature
Taipei, Taiwan	14 th November, 2025	Bill Su	C. H.

Certificate No. : TPI25344-1

* This certificate must be read in conjunction with the test report No. T11410012-2 of MIRDC.

** This certificate only confirms that the test sample (manufacturing serial number MAR39027-91D-02) complies with the relevant test process.

*** This certificate is subject to the terms of Bureau Veritas General Conditions of Service attached to the agreement signed by the applicant.

**** Detailed of fire test conditions are shown on page 2/2.

